

ECOMEN LABORATORIES PVT. LTD.

ecoMen

Flat No. 8, 2nd Floor, Arif Chamber-V, Sector H, Aliganj, Lucknow - 226 024
Phone No. : (91-522) 2746282, 2745726 Telefax No.: (91 - 522) 2745726
E-mail: ravi.bhargava@gmail.com, nikeeta@bsnl.in, Website: www.ecomen.in

An approved Laboratory from Ministry of Environment, Forest and Climate Change, Govt. of India, New Delhi (Valid Upto 02.01.19)

FORMAT NO. ECO/QS/FORMAT/07

TEST REPORT NO:ECO LAB/572/WW/03/16

TEST REPORT ISSUE DATE: 21.03.2016

TEST REPORT OF WASTE WATER*

Name of the Customer : D S C L Sugar Ajbapur
Address of the Customer : Village-Ajbapur, PO- Mullapur,
Distt. - Lakhimpur Kheri - 261505
Sampling Method : APHA (IS 3025)
Sample Collected by : Mr. Maan Singh
Date of Sampling : 15.03.2016
Type of Sample : WW (ELW-2746)
Date of Analysis : 15.03.2016 to 21.03.2016
Source of Sample : ETP Outlet

Sl. No.	TESTS	PROTOCOL	RESULT
1.	pH	APHA 22nd EDN.:2012 (4500 H+B)	7.24
2.	Total Suspended Solid as TSS (mg/l)	APHA 22nd EDN.:2012 (2540D)	22.00
3.	Total Dissolved Solids as TDS (mg/l)	APHA 22nd EDN.:2012 (2540C)	348.0
4.	Biochemical Oxygen Demand as BOD (mg/l)	APHA 22nd EDN.:2012 (5210 B)	24.0
5.	Chemical Oxygen Demand as COD (mg/l)	APHA 22nd EDN.:2012 (5220 B)	88.00
6.	Oil & Grease as O & G (mg/l)	APHA 22nd EDN.:2012 (5520 B)	BDL

*The result are related only to item tested

BDL = Below Detection Limit

Anchana
Analyst

Authorized Signatory
Ecomen Laboratories Pvt. Ltd.
Flat No. 8, 2nd Floor, Arif Chamber-V
Sector-H, Aliganj, Lucknow-226024
Ph: 2746282, Fax 2745726

Rudhique
Manager (Q)